

# BPA Air Source Heat Pump Specification

## Split and packaged:

Updated: April 4, 2022

EQUIPMENT SIZE (COOLING CAPACITY; BTU/H)	MODE	SUB-CATEGORY OR RATING CONDITION	EFFICIENCY REQUIREMENT
< 65,000	Cooling	Split System and Single Package	15.0 SEER
	Heating	Split System	8.5 HSPF
		Single Package	
≥ 65,000 and < 135,000	Cooling	Split System and Single Package	12.4 IEER
	Heating	47°F db/43°F wb Outdoor Air	3.4 COP
		17°F db/15°F wb Outdoor Air	2.3 COP
≥135,000 Btu/h and <240,000 Btu/h	Cooling	Split System and Single Package	11.6 IEER
	Heating	47°F db/43°F wb Outdoor Air	3.3 COP
		17°F db/15°F wb Outdoor Air	2.25 COP

For more information, visit [tradeallynetworknw.com](http://tradeallynetworknw.com) to contact your local utility representative or regional field specialist.