

BPA Heat Pump Specification

Air Source, split and packaged:

Updated: October 1, 2019

EQUIPMENT SIZE (COOLING CAPACITY; BTU/H)	MODE	SUB-CATEGORY OR RATING CONDITION	EFFICIENCY REQUIREMENT
< 65,000	Cooling	Split System and Single Package	16.0 SEER
	Heating	Split System	9.0 HSPF
		Single Package	8.8 HSPF
≥ 65,000 and < 135,000	Cooling	Split System and Single Package	14.0 IEER
	Heating	47°F db/43°F wb Outdoor Air	3.5 COP
		17°F db/15°F wb Outdoor Air	2.4 COP
≥ 135,000	Cooling	Split System and Single Package	12.5 IEER
	Heating	47°F db/43°F wb Outdoor Air	3.4 COP
		17°F db/15°F wb Outdoor Air	2.4 COP

For more information, visit tradeallynetworknw.com to contact your local utility representative or regional field specialist.